


MEZZANINE PLAN - POWER
SCALE: 1/8" = 1'-0"

KEYED NOTES:

- 1 NEMA TYPE 3R, 200A-3P, FUSED DISCONNECT SWITCH. MOUNT ON OR ADJACENT TO UNIT. PROVIDE FUSING AS RECOMMENDED BY MANUFACTURER.
- 2 PROVIDE SINGLE POLE TOGGLE SWITCH IN WEATHERPROOF ENCLOSURE. MOUNT ON OR ADJACENT TO UNIT.
- 3 NEMA TYPE 1, 30A-3P, FUSED DISCONNECT SWITCH. MOUNT ON OR ADJACENT TO UNIT. PROVIDE FUSING AS RECOMMENDED BY MANUFACTURER.
- 4 NEMA TYPE 1, SIZE 1, COMBINATION STARTER/DISCONNECT SWITCH.
- 5 MOUNT RECEPTACLE ON CATWALK RAILING.
- 6 FOR EACH CIRCUIT SHOWN, PROVIDE A DOUBLE DUPLEX RECEPTACLE. LOCATE DOUBLE DUPLEX RECEPTABLES ON TELECOM PLAYWOOD BACKBOARD IN LOCATION AS DIRECTED BY THE OWNER IN THE FIELD.
- 7 POWER CONNECTION FOR ALERTING SYTEM RELAY PANEL. COORDINATE LOCATION WITH THE OWNERIN THE FIELD.
- 8 PROVIDE SINGLE POLE TOGGLE SWITCH IN WEATHERPROOF ENCLOSURE FOR CONTROL OF INTERNAL UV LIGHTS. PROVIDE DOOR CONTACT SWITCH ON ACCESS DOOR TO DISCONNECT CIRCUIT IF DOOR IS OPENED. COORDINATE MOUNTING AND LOCATION WITH EQUIPMENT MECHANICAL CONTRACTOR INT HE FIELD.
- 9 MOUNT SWITCH ON OR ADJACENT TO UNIT.
- 10 PROVIDE SINGLE POLE TOGGLE SWITCH IN WEATHERPROOF ENCLOSURE. MOUNT ON OR ADJACENT TO UNIT. PROVIDE OCCUPANCY SENSOR IN EXERCISE ROOM FOR CONTROL OF UNIT. SEE DRAWING E-200 FOR MORE INFORMATION.




HUGHES GROUP ARCHITECTS
22630 DAVIS DRIVE, SUITE 175
STERLING, VIRGINIA 20164
703.437.6600

CIVIL:
ALPHA CORPORATION
21351 Ridgeloop Circle, Suite 200
Sterling, VA 20166
(703) 450-0800


STRUCTURAL:
EHLERT-BRYAN
1451 Dolley Madison Blvd, Suite 220
McLean, VA 22101
(703) 827-9552

MECHANICAL/ELECTRICAL:
BRINJAC ENGINEERING
4000 Albermarle Street, NW
Washington, DC 20016
(202) 237-2750



PURCELLVILLE FIRE AND RESCUE
500 MAPLE AVE, BUILDING #
PURCELLVILLE, VIRGINIA
MEZZANINE PLAN - POWER

KEY PLAN



REVISIONS:

ISSUES:	BID SET
9-26-07	

STAMP AND SEAL:

DATE: 09-26-07

PROJECT NO. 0611

SHEET: E-202

SCALE: AS NOTED

NOTE:
CONTRACTOR SHALL CHECK &
VERIFY ALL DIMENSIONS &
EXISTING CONDITIONS AT SITE.

BID SET